

308310N

308300N

308290N

308280N

308270N



Fire Evacuation Key

- Existing wall to achieve min 60 minute fire rating (suitability of wall to be confirmed on site by Pure Gym Main Contractor)
- New wall to achieve min of 60min fire rating
- Protected areas: walls, floors, ceilings and doors to achieve 60 minute fire resistant construction.
- M FD30 - Fire Door 60min Resistance.
- M FD60 - Fire Door 60min Resistance.
- Dis. Ref. Disabled Refuge Area - 900 x 1400mm
- 30 Occupancy level within area
- Escape Route Unprotected
- ↘ Escape Direction Angle
- ↔ Escape Route Protected/Shared
- Minimum Clear Widths
- 0 Exit No.

Fire Alarm
Fire Alarm designed and installed to BS 5839. Smoke & heat detection / emergency lighting by specialist. Please refer to MSE engineer's drawings / specifications.

Escape Lighting
Emergency lighting designed and installed to BS 5266. Part 1. Please refer to MSE Engineer's drawings / specification.

Escape Route Widths
In line with Sections 3.21.6, 3.22 of 'Approved Document Part B, Volume 2 - buildings other than dwellings' - the adjacent calculations provide justification for the clear opening widths for escape from each floor level / room in accordance with Table 4.4. appendix c.

Rev	Date	Description	DRAWING TITLE	Drawn/ Checked
PROJECT TITLE Norwich - Castle Mall Unit 2, Level 1, 100 Castle Meadow, Norwich NR1 3DD				
DRAWING TITLE Fire Escape Plan				
DRAWN / CHECKED		DATE	SCALE	DRAWING NO.
EK/PG		15.03.18	1:100 @ A1	IA-LBF-026 / 005-FEP
CONSTRUCTION				
				Pure Gym Ltd Town Centre House The Merton Centre Leeds LS2 8LY e: architecture@puregym.com t: 0113 285 8787 w: www.puregym.com